SINGAPORE CIVIL DEFENCE FORCE
FIRE SAFETY AND SHELTER DEPARTMENT

HQ SINGAPORE CIVIL DEFENCE FORCE
91 Ubi Avenue 4 Singapore 408827
Website: http//:www.scdf.gov.sg

CD/FSSD/12/01/03/04

DID: 68481407
FAX: 68481493

07 March 2008

Registrar, Board of Architects (BOA)
Registrar, Professional Engineers Board (PEB)
President, Singapore Institute of Architects (SIA)
President, Institution of Engineers, Singapore (IES)
President, Association of Consulting Engineers, Singapore (ACES)

Dear Sirs

PHOTO LUMINESCENT MARKING

A concern was raised at the recent FSSD Standing Committee that many Qualified Persons are not aware of the new requirements stated in Fire Code 2007 on the provision of photo luminescent marking/tape in buildings.

2.   This circular is to remind Qualified Persons on the need to comply with the requirements to provide photo luminescent marking/tape to guide occupants along evacuation routes to appropriate exits. The relevant requirements are stated in Cl. 2.10.3 and 2.10.4 of the Fire Code 2007.

3.   Please convey the contents of this circular to members of your Institution/Association/Board. The circular is also available in CORENET-e-Info: http://www.corenet.gov.sg/einfo.

4.   For any inquiry or clarification, please contact Maj. Choh Choon Jin at tel. no. 68481454 or email address Choh_Choon_Jin@scdf.gov.sg.

Please quote our ref. no. in all future correspondences

Yours faithfully,

(Transmitted thru' e-mail)

Poon Keng Soon
Secretary, FSSD Standing Committee
for Commissioner
Singapore Civil Defence Force

cc
All members of FSSD Standing Committee
President, REDAS
President, IFE
President, SISV
CEO, BCA
CEO, URA
CEO, HDB
CEO, PSA
CEO, JTC
CE, LTA
CE, PSB – (Attn: Ms Tan Chiew Wan / Mr Lau Keong Ong)
GM, SPRING Singapore – (Attn: Mr Teo Nam Kuan)

A PROUD MEMBER OF THE HOME TEAM