

Our Ref: BCA ID 89.11.1 Vol 1

Date: 31 Oct 2012

Technology Development Group
Tel : 6325 5914
Fax: 6325 4800
Email: jeffery_neng@bca.gov.sg

See Distribution

Dear Sir/Madam

**BUILDING CONTROL (ENVIRONMENTAL SUSTAINABILITY) REGULATIONS -
ADOPTION OF NEW CODE AND STANDARD & SUBMISSION REQUIREMENT**

Objective

1 This circular is to inform the industry on the adoption of the following codes and standards for the compliance with the Building Control (Environmental Sustainability) Regulations. They are:

- (i) BCA Green Mark Certification Standard for New Buildings (GM Version 4.1); and
- (ii) Code for Environmental Sustainability of Buildings (3rd Edition)

Building works on GLS Programme that are subject to BCA Green Mark Certification Standard for New Buildings (GM Version 4.1)

2 The BCA Green Mark Certification Standard for New Buildings (GM Version 4.1) will apply to building works relating to any building on land sold under the Government Land Sales (GLS) Programme where the GLS tender closes **on or after 15 Jan 2013** in the following selected strategic areas :

- (a) Marina Bay and Downtown Core ;
- (b) Jurong Lake District (include Jurong Gateway);
- (c) Kallang Riverside; and
- (d) Paya Lebar Central

3 The building works mentioned in above paragraph 2 must meet the prescribed Green Mark certification as set out in The Schedule of the Building Control (Environmental Sustainability) Regulations before a TOP may be granted. The assessment of the environmental

performance of these building will have to be carried out based on the BCA Green Mark Certification Standard for New Buildings (GM Version 4.1), which is available in our website at http://www.bca.gov.sg/EnvSusLegislation/others/GM_Certification_Std2012.pdf. A summary of the main changes in comparison with the current version is attached at Annex A for reference.

Building works that are subject to Code for Environmental Sustainability of Buildings (3rd Edition)

4 The Code for Environmental Sustainability of Buildings (3rd Edition) will apply to any of the following building works where planning permissions are first submitted to Urban Redevelopment Authority (URA) **on or after 15 Jan 2013** :

- (a) Building works which involve a gross floor area of 2,000m² or more;
- (b) Building works which involve increasing the gross floor area of an existing building by 2,000m² or more; and
- (c) Building works relating to an existing building which involve a gross floor area of 2,000m² or more; and the provision, extension or substantial alteration of the building envelope and building services.

5 The Code for Environmental Sustainability of Buildings (3rd Edition) is available in our website at: http://www.bca.gov.sg/EnvSusLegislation/others/Env_Sus_Code2012.pdf. A summary of the main changes in comparison with the current Code is attached at Annex B for reference.

Submission Requirement

6 Currently, the QP and other appropriate practitioners are required to jointly submit the Green Mark Score and declaration for the building works, stated in paragraph (4), together with the building plan for approval. To facilitate better understanding of the proposed building cooling system design and efficiency, we would like the cooling system information to be submitted in prescribed format by the appropriate practitioner (i.e PE(Mech), together with the Green Mark score calculation and declaration. Time extension can be considered if such details are not ready at the time of submission. The prescribed form is available in our website at:

http://www.bca.gov.sg/EnvSusLegislation/others/Air-Con_Info_Template.xls

7 The Code for Environmental Sustainability of Buildings (3rd Edition) has incorporated a separate non-residential building criteria that specifically cater to the design and construction of Transit Stations. With effect from **15 Jan 2013**, the Qualified Person and other appropriate practitioners handling such projects will use these criteria for compliance. These building works are required to meet the minimum Green Mark Score of 50 points and pre-requisite requirements prior to obtaining building plan approval and TOP clearance at later stage.

For Clarification

8. We would appreciate it if you could convey the contents of this circular to members of your organization. For clarification, you may email to bca_enquiry@bca.gov.sg or contact the following officers :

Subject Matter	Name	Email	Contact No.
Regulatory submission pertaining to Environmental Sustainability Requirement and Green Mark Criteria	Grace Cheok	grace_cheok-chan@bca.gov.sg	63257588
	Leow Yock Keng	leow_yock_keng@bca.gov.sg	63257525
Legislative requirement pertaining to Government Land Sale (GLS) Programme	Tan Chee Keong	tan_chee_keong@bca.gov.sg	63255617
	Joseph Hong	Joseph_hong@bca.gov.sg	63257795

Thank you.

Yours faithfully



JEFFERY NENG
DIRECTOR
TECHNOLOGY DEVELOPMENT GROUP
for COMMISSIONER OF BUILDING CONTROL

DISTRIBUTION (via e-mail):

President
Real Estate Developer Association of Singapore (REDAS)
190 Clemenceau Avenue
#07-01 Singapore Shopping Centre
Singapore 239924
enquiry@redas.com

President
Singapore Institute of Architects (SIA)
79 Neil Road
Singapore 088904
info@sia.org.sg

President
Institution of Engineers, Singapore (IES)
70, Bukit Tinggi Road
Singapore 289758
iesnet@singnet.com.sg

President
Association of Consulting Engineers Singapore (ACES)
Thomson Road Post Office
PO Box 034
Singapore 915702
secretariat@aces.org.sg

President
Singapore Contractors Association Limited (SCAL)
1 Bukit Merah Lane 2
Construction House
Singapore 159760
enquiry@scal.com.sg

President
Society of Project Managers (SPM)
Macpherson Road P.O.Box 1083
Singapore 913412
sprojm@yahoo.com

President
Singapore Institute of Building Limited (SIBL)
70 Palmer Road,
#03-09C Palmer House
Singapore 079427
josephine@sib.com.sg

President
Singapore Institute of Surveyors & Valuers (SISV)
20 Maxwell Road, #10-09B, Maxwell House
Singapore 069113
sisv.info@sisv.org.sg

President
Singapore Institute of Planners (SIP)
71A Kampong Bahru Road
Singapore 169373
info@sip.org.sg

President
Association of Property & Facility Managers (APFM)
20 Maxwell Road, #10-09B Maxwell House
Singapore 069113
apfm@pacific.net.sg

Registrar
Board of Architects (BOA)
5 Maxwell Road 1st storey
Tower Block MND Complex
Singapore 069110
boarch@singnet.com.sg

Registrar
Professional Engineers Board, Singapore
5 Maxwell Road
1st Storey Tower Block MND Complex
Singapore 069110
registrar@peb.gov.sg

All CORENET e-info subscribers

BCA Green Mark Certification Standard for New Buildings (GM Version 4.1)



Annex A

Summary of the Main Changes

Green Mark for New Residential Building Criteria

Green Mark for New Non-Residential Building Criteria

Criteria / Requirements	Green Mark Version RB 4.0	Green Mark Version RB 4.1
<p>1. VENTILATION SIMULATION METHODOLOGY</p> <p>Pre-requisite Requirement RB 1-2</p> <p>APPENDIX C</p>	<p>1.1 To be eligible for Green Mark Platinum rating, it is a requirement to use ventilation simulation modeling and analysis to identify the most effective building design and layout. A minimum 80% of the selected typical dwelling units should have a weighted average wind velocity of 0.60 m/s.</p> <p>1.2 The ventilation simulation modelling to be conducted based on the four prevailing wind directions for the building development namely North, North-East, South and South-East.</p>	<p>1.1 A minimum 70% of the selected typical dwelling units will be required in considering the weighted average wind velocity instead of 80%.</p> <p>1.2 The ventilation simulation modelling can be conducted based on the two best prevailing wind directions for the building development that is North or North-East (N or NE) and South or South-East (S or SE).</p>
Criteria / Requirements	Green Mark Version NRB 4.0	Green Mark Version NRB 4.1
<p>2. AIR CONDITIONING SYSTEM SCORING AND METHODOLOGY</p> <p>NRB 1-2 (a) – Water Cooled Chilled-Water Plant</p>	<p>2.1 Scoring methodology was based on the cooling load profile for a design peak day, building operating hours specified and the chilled water plant efficiency at full load condition or part load condition</p>	<p>2.1 Scoring methodology was revised to consider the building cooling load profile for a typical week and building operating hours specified. The Design System Efficiency (DSE) of the proposed air-conditioning system will be based on the total average cooling load and total power inputs of the various system components.</p> <p>For potential Green Mark Gold^{Plus} and Platinum projects, the scoring will be based on the Design System Efficiency (DSE) derived using the energy modeling framework set out in Appendix E.</p>

Criteria / Requirements	Green Mark Version NRB 4.0	Green Mark Version NRB 4.1																	
<p>3. MECHANICAL VENTILATION FAN SYSTEM SCORING</p> <p>NRB 1-4 Mechanical Ventilation</p>	<p>The baseline standard adopted for fan system was only based on allowable motor nameplate as shown below.</p> <p><u>Baseline</u>: SS553:2009 Table 8 – Fan power limitation in mechanical ventilation systems</p> <table border="1" data-bbox="667 459 1258 555"> <thead> <tr> <th colspan="2">Allowable nameplate motor power</th> </tr> <tr> <th>Constant volume</th> <th>Variable volume</th> </tr> </thead> <tbody> <tr> <td>1.7 kW/m³/s</td> <td>2.4 kW/m³/s</td> </tr> </tbody> </table>	Allowable nameplate motor power		Constant volume	Variable volume	1.7 kW/m ³ /s	2.4 kW/m ³ /s	<p>The baseline standard using fan system input power was introduced as Option 2.</p> <p><u>Option 2 – Fan System Input Power</u></p> <p><u>Baseline</u> : ASHRAE 90.1 : 2010 Clause 6.5.3.1 and as prescribed below :</p> <table border="1" data-bbox="1294 448 1917 762"> <thead> <tr> <th rowspan="2">Air Distribution System Type</th> <th colspan="2">Allowable Fan System Input Power *</th> </tr> <tr> <th>(kW/m³/s)</th> <th>(W/CMH)</th> </tr> </thead> <tbody> <tr> <td>AHUs/FCUs ≥ 4kW (Constant Volume)</td> <td>1.5</td> <td>0.42</td> </tr> <tr> <td>Fan systems with nameplate motor power < 4 kW</td> <td>0.6</td> <td>0.17</td> </tr> </tbody> </table> <p>* Applicable pressure drop adjustments can be considered based on ASHRAE 90.1 Table 6.5.3.1.1B and are subject to BCA's evaluation</p>	Air Distribution System Type	Allowable Fan System Input Power *		(kW/m ³ /s)	(W/CMH)	AHUs/FCUs ≥ 4kW (Constant Volume)	1.5	0.42	Fan systems with nameplate motor power < 4 kW	0.6	0.17
Allowable nameplate motor power																			
Constant volume	Variable volume																		
1.7 kW/m ³ /s	2.4 kW/m ³ /s																		
Air Distribution System Type	Allowable Fan System Input Power *																		
	(kW/m ³ /s)	(W/CMH)																	
AHUs/FCUs ≥ 4kW (Constant Volume)	1.5	0.42																	
Fan systems with nameplate motor power < 4 kW	0.6	0.17																	
<p>4. ENERGY MODELLING FRAMEWORK</p> <p>Under Table E3 – Baseline Standard</p> <p>Item No. 2.5 – Air-Conditioning Fan Systems</p>	<p>4.1 The baseline standard adopted for air-conditioning fan system under Table E3 was based on <u>allowable name plate motor power</u> where the ratio of fan system power to the supply fan air flow rate (main fan) of each air air-conditioning system at design conditions shall not exceed allowable fan system power stated below</p> <p>Constant Volume shall not exceed 1.7 kW/m³/s of supply air</p> <p>Variable Volume shall not exceed 2.4 kW/m³/s of supply air</p>	<p>4.1 The baseline standard adopted for air-conditioning fan system under Table E3 was based on <u>allowable fan system input power</u>.</p> <p>For fan system having a motor nameplate power exceeding 4 kW, the fan power limitation in air-conditioning system that is the allowable fan system input power shall be as follows :</p> <p>(i) Constant volume shall not exceed 1.5 kW/m³/s (or 0.42 W/CMH) of supply air</p> <p>(ii) Variable volume shall not exceed 2.1 kW/m³/s (or 0.58 W/CMH) of supply air</p> <p>(b) For fan system having a motor nameplate power not exceeding 4 kW, the allowable fan system input power shall not exceed 0.6 kW/m³/s (or 0.17 W/CMH) of supply air.</p>																	

Criteria / Requirements	Green Mark Version NRB 4.0	Green Mark Version NRB 4.1												
<p>4. ENERGY MODELLING FRAMEWORK</p> <p>Cont'd</p> <p>Item No. 2.6 – Mechanical Ventilation Fan Systems</p>	<p>4.2 The ratio of fan system to the supply fan air flow rate (main fan) of each mechanical ventilation system at design conditions shall not exceed allowable fan system power.</p> <p>Fan power limitation in mechanical ventilation system – Allowable nameplate motor power</p> <ul style="list-style-type: none"> (i) Constant volume shall not exceed 1.7 kW/m³/s of supply air (ii) Variable volume shall not exceed 2.4 kW/m³/s of supply air 	<p>4.2 The ratio of fan system to the supply fan air flow rate (main fan) of each mechanical ventilation system at design conditions shall not exceed allowable fan system power.</p> <p>Fan system design criteria</p> <p>(a) For fan system having a motor nameplate power exceeding 4 kW, the fan power limitation in air-conditioning system that is the allowable fan system input power shall not exceed 1.5 kW/m³/s (or 0.42 W/CMH) of supply air</p> <p>(b) For fan system having a motor nameplate power not exceeding 4 kW, fan system input power shall not exceed 0.6 kW/m³/s (or 0.17 W/CMH) of supply air.</p>												
<p>Item No. 2.7 – Lighting Systems</p>	<p>4.3 The baseline standard for lighting systems – SS 530 – Code of Practice for Energy Efficiency Standard for Building Services and Equipment</p>	<p>4.3 Lighting power budgets for common areas were specified for use. The allowable lighting power density stated in ASHRAE 90.1 can be considered if the lighting power budget for the types of usage are not made available in SS 530</p>												
<p>New Item No. 3.7</p>	<p>4.3 No Provision</p>	<p>4.3 For projects that demonstrate considerable efforts to reduce air-conditioned space and hence greater energy savings, a cap of 2% additional energy savings over its reference model can be considered for such efforts.</p> <p><i>Note: Provision does not apply to areas that would normally be non air-conditioned space.</i></p>												
<p>Paragraph E4.5</p>	<p>4.4 No specific mention</p>	<p>4.4 The basis for deriving the overall energy consumption and potential energy savings must be made clear and justifiable for consideration. Notwithstanding this, the cap on the potential energy savings for the following systems/devices may be imposed based on the following norm :</p> <table border="1" data-bbox="1301 1155 2074 1335"> <thead> <tr> <th data-bbox="1301 1155 1839 1185">List of Systems/Devices</th> <th data-bbox="1839 1155 2074 1185">Energy savings Cap</th> </tr> </thead> <tbody> <tr> <td data-bbox="1301 1185 1839 1216">Escalator</td> <td data-bbox="1839 1185 2074 1216">30%</td> </tr> <tr> <td data-bbox="1301 1216 1839 1262">Lifts</td> <td data-bbox="1839 1216 2074 1262">10%</td> </tr> <tr> <td data-bbox="1301 1262 1839 1292">CO sensors</td> <td data-bbox="1839 1262 2074 1292">15%</td> </tr> <tr> <td data-bbox="1301 1292 1839 1323">Occupancy Sensors</td> <td data-bbox="1839 1292 2074 1323">15%</td> </tr> <tr> <td data-bbox="1301 1323 1839 1335">Photo Sensors</td> <td data-bbox="1839 1323 2074 1335">15%</td> </tr> </tbody> </table>	List of Systems/Devices	Energy savings Cap	Escalator	30%	Lifts	10%	CO sensors	15%	Occupancy Sensors	15%	Photo Sensors	15%
List of Systems/Devices	Energy savings Cap													
Escalator	30%													
Lifts	10%													
CO sensors	15%													
Occupancy Sensors	15%													
Photo Sensors	15%													

Criteria / Requirements	Green Mark Version NRB 4.0	Green Mark Version NRB 4.1																									
<p>5. PRE-REQUISITE REQUIREMENT PERTAINING TO ENERGY MODELLING AND VENTILATION SIMULATION</p>	No Provision	<p><u>NEW PREQUISITE</u></p> <p><u>Building Developments with more than 30% Non Air-Conditioned Spaces</u></p> <p>Prerequisite requirement for building developments with a combination of ventilation mode and with aggregate non-air-conditioned spaces of more than 30% of the total constructed floor areas (excluding carparks and common areas) are as follows :</p> <table border="1" data-bbox="1294 475 2094 775"> <thead> <tr> <th data-bbox="1294 475 1435 619">Aggregate Non Air-Conditioned Spaces (m²)</th> <th data-bbox="1435 475 1621 619">Aggregate Air-Conditioned Spaces (m²)</th> <th data-bbox="1621 475 1776 619">Ventilation Simulation Requirement</th> <th data-bbox="1776 475 1939 619">Energy Modeling Requirement</th> <th data-bbox="1939 475 2094 619">Justification on Energy Savings</th> </tr> </thead> <tbody> <tr> <td data-bbox="1294 619 1435 655">≥ 2000</td> <td data-bbox="1435 619 1621 655">≥ 5000</td> <td data-bbox="1621 619 1776 655">Yes</td> <td data-bbox="1776 619 1939 655">Yes</td> <td data-bbox="1939 619 2094 655">No</td> </tr> <tr> <td data-bbox="1294 655 1435 692">< 2000</td> <td data-bbox="1435 655 1621 692">≥ 5000</td> <td data-bbox="1621 655 1776 692">No</td> <td data-bbox="1776 655 1939 692">Yes</td> <td data-bbox="1939 655 2094 692">No</td> </tr> <tr> <td data-bbox="1294 692 1435 729">≥ 2000</td> <td data-bbox="1435 692 1621 729">< 5000</td> <td data-bbox="1621 692 1776 729">Yes</td> <td data-bbox="1776 692 1939 729">No</td> <td data-bbox="1939 692 2094 729">Yes</td> </tr> <tr> <td data-bbox="1294 729 1435 766">< 2000</td> <td data-bbox="1435 729 1621 766">< 5000</td> <td data-bbox="1621 729 1776 766">No</td> <td data-bbox="1776 729 1939 766">No</td> <td data-bbox="1939 729 2094 766">Yes</td> </tr> </tbody> </table>	Aggregate Non Air-Conditioned Spaces (m ²)	Aggregate Air-Conditioned Spaces (m ²)	Ventilation Simulation Requirement	Energy Modeling Requirement	Justification on Energy Savings	≥ 2000	≥ 5000	Yes	Yes	No	< 2000	≥ 5000	No	Yes	No	≥ 2000	< 5000	Yes	No	Yes	< 2000	< 5000	No	No	Yes
Aggregate Non Air-Conditioned Spaces (m ²)	Aggregate Air-Conditioned Spaces (m ²)	Ventilation Simulation Requirement	Energy Modeling Requirement	Justification on Energy Savings																							
≥ 2000	≥ 5000	Yes	Yes	No																							
< 2000	≥ 5000	No	Yes	No																							
≥ 2000	< 5000	Yes	No	Yes																							
< 2000	< 5000	No	No	Yes																							
Criteria / Requirements	Green Mark Version RB 4.0 and NRB 4.0	Green Mark Version RB 4.1 and NRB 4.1																									
<p>6. ENERGY EFFICIENT PRODUCTS OR EQUIPMENT</p> <p>RB 1-7</p> <p>NRB 1-10</p>	No Provision	<p><u>NEW CRITERIA UNDER RB 1-7 AND NRB 1-10</u></p> <p>Use of energy efficient equipment or product that are certified by approved local certification body</p> <p>Extent of Coverage : 90% of the applicable equipment type or product</p> <p>0.5 point for each eligible certified equipment or products (Up to 2 points)</p>																									

Criteria / Requirements	Green Mark Version RB 4.0 and NRB 4.0	Green Mark Version RB 4.1 and NRB 4.1																
<p>7. SUSTAINABLE CONSTRUCTION</p> <p>RB 3-1(a)(ii) NRB 3-1(a)(ii)</p>	<p>Extent of Coverage : The total quantity used (in tonnage) for replacement of the coarse or fine aggregates must not be less than the minimum usage requirement that is [0.03 x Gross Floor Area (GFA in m²)]</p> <p>2 points for the use of RCA to replace coarse aggregates</p> <p>2 points for the use of WCS to replace fine aggregates</p> <p>Where the total quantity used (in tonnage) for replacement of coarse or fine aggregates is at least two times (2x) that of the minimum usage requirement.</p> <p>4 points for the use of RCA</p> <p>4 points for the use of WCS</p>	<p>The point scoring will be based on the quantity used (in tonnage) as illustrated below :</p> <p>1 point for every incremental of 0.5 times (0.5x) of the usage requirement. (Up to 2x)</p> <table border="1" data-bbox="1323 411 2011 651"> <thead> <tr> <th>Quantity of RCA /WCS</th> <th>Points Allocation</th> </tr> </thead> <tbody> <tr> <td>≥ 0.5 x usage requirement</td> <td>1 point</td> </tr> <tr> <td>≥ 1.0 x usage requirement</td> <td>2 points</td> </tr> <tr> <td>≥ 1.5 x usage requirement</td> <td>3 points</td> </tr> <tr> <td>≥ 2.0 x usage requirement</td> <td>4 points</td> </tr> </tbody> </table> <p>where usage requirement = 0.03 x Gross Floor Area (GFA in m²)</p>	Quantity of RCA /WCS	Points Allocation	≥ 0.5 x usage requirement	1 point	≥ 1.0 x usage requirement	2 points	≥ 1.5 x usage requirement	3 points	≥ 2.0 x usage requirement	4 points						
Quantity of RCA /WCS	Points Allocation																	
≥ 0.5 x usage requirement	1 point																	
≥ 1.0 x usage requirement	2 points																	
≥ 1.5 x usage requirement	3 points																	
≥ 2.0 x usage requirement	4 points																	
<p>8. SUSTAINABLE PRODUCTS</p> <p>RB 3-2 NRB 3-2</p>	<p>The weightages given will be based on the extent of environmental friendliness as determined by the approved local certification body and are subject to BCA's evaluation were as follows.</p> <table border="1" data-bbox="674 986 1193 1238"> <thead> <tr> <th>Extent of Environmental Friendliness of Products</th> <th>Weightage for Point Allocation</th> </tr> </thead> <tbody> <tr> <td>Good</td> <td>1</td> </tr> <tr> <td>Very Good</td> <td>1.5</td> </tr> <tr> <td>Excellent</td> <td>2</td> </tr> </tbody> </table>	Extent of Environmental Friendliness of Products	Weightage for Point Allocation	Good	1	Very Good	1.5	Excellent	2	<p>The weightage given for the 'Good' rating was reduced to 0.5 instead of 1 as illustrated in the following table :</p> <table border="1" data-bbox="1305 927 1825 1179"> <thead> <tr> <th>Extent of Environmental Friendliness of Products</th> <th>Weightage for Point Allocation</th> </tr> </thead> <tbody> <tr> <td>Good</td> <td>0.5</td> </tr> <tr> <td>Very Good</td> <td>1.5</td> </tr> <tr> <td>Excellent</td> <td>2</td> </tr> </tbody> </table> <p>Note: There is a new pre-requisite requirement for higher GM rating projects</p> <p>Minimum score under RB 3-2 and NRB 3-2 Sustainable Products</p> <p>Green Mark Gold^{Plus} ≥ 3 points</p> <p>Green Mark Platinum ≥ 4 points</p>	Extent of Environmental Friendliness of Products	Weightage for Point Allocation	Good	0.5	Very Good	1.5	Excellent	2
Extent of Environmental Friendliness of Products	Weightage for Point Allocation																	
Good	1																	
Very Good	1.5																	
Excellent	2																	
Extent of Environmental Friendliness of Products	Weightage for Point Allocation																	
Good	0.5																	
Very Good	1.5																	
Excellent	2																	

Criteria / Requirements	Green Mark Version RB 4.0 and NRB 4.0	Green Mark Version RB 4.1 and NRB 4.1
<p>9. GREENERY PROVISION</p> <p>RB 3-3</p> <p>NRB 3-3</p>	<p>No mention</p>	<p><u>EXCEPTION CLAUSE INCLUDED</u></p> <p><u>Trees and Palms Spacing (Centre to Centre)</u> (a) If the selected trees and palms are to be planted at $\leq 2\text{m}$ from trunk-to-trunk as illustrated below, the leaf area should be calculated as the product of LAI value and planted area (in m^2).</p> <p><u>Columnar Trees</u> (b) For trees that have tight, columnar crowns, the canopy area of 12 m^2 is to be adopted for calculation of leaf area.</p>
<p>10. GREEN TRANSPORT</p> <p>RB 3-5(c)</p> <p>NRB 3-5(c)</p>	<p>No specific mention on the extent of coverage for the provision of electric vehicle charging stations and priority parking lots within the development.</p>	<p><u>For RB 3-5(c)</u> Extent of Coverage : Minimum 1 number of electric vehicle charging station for every 100 carpark lots (Cap at 5) 1 point</p> <p><u>For NRB 3-5(c)</u> Extent of Coverage : Minimum 1 number of electric vehicle charging station and priority parking lot for every 100 carpark lots (Cap at 5) 1 point</p>
<p>11. OTHER GREEN FEATURES</p> <p>RB 5-1</p> <p>NRB 5-1</p>	<p>No Provision</p>	<p><u>NEW CRITERIA UNDER RB 5-1 and NRB 5-1</u></p> <p>1 point allocated for the computation of concrete usage index of the development</p>
<p>12. PRE-REQUISITE REQUIREMENT PERTAINING TO THE USE OF SUSTAINABLE PRODUCTS</p>	<p>No Provision</p>	<p><u>NEW PREQUISITE</u></p> <p>Minimum score under RB 3-2 and NRB 3-2 Sustainable Products Green Mark Gold^{Plus} ≥ 3 points Green Mark Platinum ≥ 4 points</p>

Annex B

Summary of the Main Changes and Additions

Residential Building Criteria

Non-Residential Building Criteria

Transit Stations

Criteria / Requirements	Code (2 nd Edition) Residential Building Criteria	Code (3 th Edition) Residential Building Criteria																							
1. VENTILATION SIMULATION METHODOLOGY RB 1-2 & ANNEX C	1.1 The ventilation simulation modelling to be conducted based on the four prevailing wind directions for the building development namely North, North-East, South and South-East.	1.1 The ventilation simulation modelling can be conducted based on the two best prevailing wind directions for the building development that is North or North-East (N or NE) and South or South-East (S or SE).																							
Criteria / Requirements	Code (2 nd Edition) Non-Residential Building Criteria	Code (3 th Edition) Non-Residential Building Criteria																							
2. AIR CONDITIONING SYSTEM SCORING AND METHODOLOGY NRB 1-2 (a) – Water Cooled Chilled-Water Plant NRB 1-2 (c) – Air Distribution System	2.1 Scoring methodology was based on the cooling load profile for a design peak day, building operating hours specified and the chilled water plant efficiency at full load condition or part load condition 2.2 No baseline and consideration for fan systems with power of $\leq 4\text{kW}$ in SS 553 2.3 The baseline standard adopted for fan system was only based on allowable motor nameplate as shown below. <u>Baseline</u> : SS553:2009 Table 2 – Fan power limitation in air-conditioning systems <table border="1" data-bbox="667 1046 1256 1157"> <thead> <tr> <th colspan="2">Allowable nameplate motor power</th> </tr> <tr> <th>Constant volume</th> <th>Variable volume</th> </tr> </thead> <tbody> <tr> <td>1.7 kW/m³/s</td> <td>2.4 kW/m³/s</td> </tr> </tbody> </table>	Allowable nameplate motor power		Constant volume	Variable volume	1.7 kW/m ³ /s	2.4 kW/m ³ /s	2.1 Scoring methodology was revised to consider the building cooling load profile for a typical week and building operating hours specified. The Design System Efficiency (DSE) of the proposed air-conditioning system will be based on the total average cooling load and total power inputs of the various system components. 2.2 A baseline was established and set at 0.17 W/CMH or 0.6 kW/m ³ /s 2.3 The baseline standard using fan system input power was introduced as Option 2. <u>Option 2 – Fan System Input Power</u> <u>Baseline</u> : ASHRAE 90.1:2010 Clause 6.5.3.1 and as prescribed below : <table border="1" data-bbox="1294 995 2092 1283"> <thead> <tr> <th rowspan="2">Baseline</th> <th colspan="2">Allowable Fan System Input Power*</th> </tr> <tr> <th>(kW/m³/s)</th> <th>(W/CMH)</th> </tr> </thead> <tbody> <tr> <td>Air Distribution System Type</td> <td></td> <td></td> </tr> <tr> <td>AHUs/FCUs $\geq 4\text{kW}$ (Constant Volume)</td> <td>1.5</td> <td>0.42</td> </tr> <tr> <td>AHUs $\geq 4\text{kW}$ (Variable Volume)</td> <td>2.1</td> <td>0.58</td> </tr> <tr> <td>Fan systems with nameplate motor power $< 4\text{ kW}$</td> <td>0.6</td> <td>0.17</td> </tr> </tbody> </table> <p>* Applicable pressure drop adjustments can be considered based on ASHRAE 90.1 Table 6.5.3.1.1B and are subject to BCA's evaluation</p>	Baseline	Allowable Fan System Input Power*		(kW/m ³ /s)	(W/CMH)	Air Distribution System Type			AHUs/FCUs $\geq 4\text{kW}$ (Constant Volume)	1.5	0.42	AHUs $\geq 4\text{kW}$ (Variable Volume)	2.1	0.58	Fan systems with nameplate motor power $< 4\text{ kW}$	0.6	0.17
Allowable nameplate motor power																									
Constant volume	Variable volume																								
1.7 kW/m ³ /s	2.4 kW/m ³ /s																								
Baseline	Allowable Fan System Input Power*																								
	(kW/m ³ /s)	(W/CMH)																							
Air Distribution System Type																									
AHUs/FCUs $\geq 4\text{kW}$ (Constant Volume)	1.5	0.42																							
AHUs $\geq 4\text{kW}$ (Variable Volume)	2.1	0.58																							
Fan systems with nameplate motor power $< 4\text{ kW}$	0.6	0.17																							

Criteria / Requirements	Code (2 nd Edition) Non-Residential Building Criteria	Code (3 th Edition) Non-Residential Building Criteria																	
<p>2. AIR CONDITIONING SYSTEM SCORING AND METHODOLOGY</p> <p>Cont'd</p> <p>NRB 1-2 (d) – Instrumentation for Monitoring Central Water Cooled Chilled Water Plant Efficiency</p>	<p>2.4 No specific mention</p>	<p>2.4 To include the provision for dedicated power meters for each of the following groups of equipment: chillers, chilled water pumps, condenser water pumps and cooling towers under NRB 1-2(d)(vi).</p>																	
<p>3. MECHANICAL VENTILATION FAN SYSTEM SCORING</p> <p>NRB 1-4 Mechanical Ventilation</p>	<p>The baseline standard adopted for fan system was only based on allowable motor nameplate as shown below.</p> <p><u>Baseline</u>: SS553:2009 Table 8 – Fan power limitation in mechanical ventilation systems</p> <table border="1" data-bbox="667 863 1256 959"> <thead> <tr> <th colspan="2">Allowable nameplate motor power</th> </tr> <tr> <th>Constant volume</th> <th>Variable volume</th> </tr> </thead> <tbody> <tr> <td>1.7 kW/m³/s</td> <td>2.4 kW/m³/s</td> </tr> </tbody> </table>	Allowable nameplate motor power		Constant volume	Variable volume	1.7 kW/m ³ /s	2.4 kW/m ³ /s	<p>The baseline standard using fan system input power was introduced in Alternative Option 2.</p> <p><u>Option 2 – Fan System Input Power</u></p> <p><u>Baseline</u> : ASHRAE 90.1 : 2010 Clause 6.5.3.1 and as prescribed below :</p> <table border="1" data-bbox="1294 850 1917 1166"> <thead> <tr> <th rowspan="2">Baseline Air Distribution System Type</th> <th colspan="2">Allowable Fan System Input Power *</th> </tr> <tr> <th>(kW/m³/s)</th> <th>(W/CMH)</th> </tr> </thead> <tbody> <tr> <td>AHUs/FCUs ≥ 4kW (Constant Volume)</td> <td>1.5</td> <td>0.42</td> </tr> <tr> <td>Fan systems with nameplate motor power < 4 kW</td> <td>0.6</td> <td>0.17</td> </tr> </tbody> </table> <p>* Applicable pressure drop adjustments can be considered based on ASHRAE 90.1 Table 6.5.3.1.1B and are subject to BCA's evaluation</p>	Baseline Air Distribution System Type	Allowable Fan System Input Power *		(kW/m ³ /s)	(W/CMH)	AHUs/FCUs ≥ 4kW (Constant Volume)	1.5	0.42	Fan systems with nameplate motor power < 4 kW	0.6	0.17
Allowable nameplate motor power																			
Constant volume	Variable volume																		
1.7 kW/m ³ /s	2.4 kW/m ³ /s																		
Baseline Air Distribution System Type	Allowable Fan System Input Power *																		
	(kW/m ³ /s)	(W/CMH)																	
AHUs/FCUs ≥ 4kW (Constant Volume)	1.5	0.42																	
Fan systems with nameplate motor power < 4 kW	0.6	0.17																	

Criteria / Requirements	Code (2 nd Edition) Residential and Non-Residential Building Criteria	Code (3 th Edition) Residential and Non-Residential Building Criteria										
<p>4. ENERGY EFFICIENT PRODUCTS OR EQUIPMENT</p> <p>RB 1-7 NRB 1-10</p>	<p>No Provision</p>	<p><u>NEW CRITERIA UNDER RB 1-7 AND NRB 1-10</u></p> <p>Use of energy efficient equipment or product that are certified by approved local certification body</p> <p>Extent of Coverage : 90% of the applicable equipment type or product</p> <p>0.5 point for each eligible certified equipment or products (Up to 2 points)</p>										
<p>5. SUSTAINABLE CONSTRUCTION</p> <p>RB 3-1(a)(ii) NRB 3-1(a)(ii)</p>	<p>Extent of Coverage : The total quantity used (in tonnage) for replacement of the coarse or fine aggregates must not be less than the minimum usage requirement that is [0.03 x Gross Floor Area (GFA in m²)]</p> <p>2 points for the use of RCA to replace coarse aggregates</p> <p>2 points for the use of WCS to replace fine aggregates</p> <p>Where the total quantity used (in tonnage) for replacement of coarse or fine aggregates is at least two times (2x) that of the minimum usage requirement.</p> <p>4 points for the use of RCA</p> <p>4 points for the use of WCS</p>	<p>The point scoring will be based on the quantity used (in tonnage) as illustrated below :</p> <p>1 point for every incremental of 0.5 times (0.5x) of the usage requirement. (Up to 2x)</p> <table border="1" data-bbox="1323 794 2011 1034"> <thead> <tr> <th>Quantity of RCA /WCS</th> <th>Points Allocation</th> </tr> </thead> <tbody> <tr> <td>≥ 0.5 x usage requirement</td> <td>1 point</td> </tr> <tr> <td>≥ 1.0 x usage requirement</td> <td>2 points</td> </tr> <tr> <td>≥ 1.5 x usage requirement</td> <td>3 points</td> </tr> <tr> <td>≥ 2.0 x usage requirement</td> <td>4 points</td> </tr> </tbody> </table> <p>where usage requirement = 0.03 x Gross Floor Area (GFA in m²)</p>	Quantity of RCA /WCS	Points Allocation	≥ 0.5 x usage requirement	1 point	≥ 1.0 x usage requirement	2 points	≥ 1.5 x usage requirement	3 points	≥ 2.0 x usage requirement	4 points
Quantity of RCA /WCS	Points Allocation											
≥ 0.5 x usage requirement	1 point											
≥ 1.0 x usage requirement	2 points											
≥ 1.5 x usage requirement	3 points											
≥ 2.0 x usage requirement	4 points											

Criteria / Requirements	Code (2 nd Edition) Residential and Non-Residential Building Criteria	Code (3 th Edition) Residential and Non-Residential Building Criteria																
<p>6. SUSTAINABLE PRODUCTS</p> <p>RB 3-2 NRB 3-2</p>	<p>The weightages given will be based on the extent of environmental friendliness as determined by the approved local certification body and are subject to BCA's evaluation were as follows.</p> <table border="1" data-bbox="674 405 1193 660"> <thead> <tr> <th data-bbox="674 405 954 528">Extent of Environmental Friendliness of Products</th> <th data-bbox="954 405 1193 528">Weightage for Point Allocation</th> </tr> </thead> <tbody> <tr> <td data-bbox="674 528 954 571">Good</td> <td data-bbox="954 528 1193 571">1</td> </tr> <tr> <td data-bbox="674 571 954 614">Very Good</td> <td data-bbox="954 571 1193 614">1.5</td> </tr> <tr> <td data-bbox="674 614 954 660">Excellent</td> <td data-bbox="954 614 1193 660">2</td> </tr> </tbody> </table>	Extent of Environmental Friendliness of Products	Weightage for Point Allocation	Good	1	Very Good	1.5	Excellent	2	<p>The weightage given for the 'Good' rating was reduced to 0.5 instead of 1 as illustrated in the following table :</p> <table border="1" data-bbox="1305 347 1825 603"> <thead> <tr> <th data-bbox="1305 347 1585 470">Extent of Environmental Friendliness of Products</th> <th data-bbox="1585 347 1825 470">Weightage for Point Allocation</th> </tr> </thead> <tbody> <tr> <td data-bbox="1305 470 1585 513">Good</td> <td data-bbox="1585 470 1825 513">0.5</td> </tr> <tr> <td data-bbox="1305 513 1585 557">Very Good</td> <td data-bbox="1585 513 1825 557">1.5</td> </tr> <tr> <td data-bbox="1305 557 1585 603">Excellent</td> <td data-bbox="1585 557 1825 603">2</td> </tr> </tbody> </table>	Extent of Environmental Friendliness of Products	Weightage for Point Allocation	Good	0.5	Very Good	1.5	Excellent	2
Extent of Environmental Friendliness of Products	Weightage for Point Allocation																	
Good	1																	
Very Good	1.5																	
Excellent	2																	
Extent of Environmental Friendliness of Products	Weightage for Point Allocation																	
Good	0.5																	
Very Good	1.5																	
Excellent	2																	
<p>7. GREENERY PROVISION</p> <p>RB 3-3 NRB 3-3</p>	<p>No mention</p>	<p><u>EXCEPTION CLAUSE INCLUDED</u></p> <p><u>Trees and Palms Spacing (Centre to Centre)</u> (a) If the selected trees and palms are to be planted at $\leq 2\text{m}$ from trunk-to-trunk as illustrated below, the leaf area should be calculated as the product of LAI value and planted area (in m^2).</p> <p><u>Columnar Trees</u> (b) For trees that have tight, columnar crowns, the canopy area of 12m^2 is to be adopted for calculation of leaf area.</p>																
<p>8. GREEN TRANSPORT</p> <p>RB 3-5(c) NRB 3-5(c)</p>	<p>No specific mention on the extent of coverage for the provision of electric vehicle charging stations and priority parking lots within the development.</p>	<p><u>For RB 3-5(c)</u> Extent of Coverage : Minimum 1 number of electric vehicle charging station for every 100 carpark lots (Cap at 5) 1 point</p> <p><u>For NRB 3-5(c)</u> Extent of Coverage : Minimum 1 number of electric vehicle charging station and priority parking lot for every 100 carpark lots (Cap at 5) 1 point</p>																

Criteria / Requirements	Code (2 nd Edition) Residential and Non-Residential Building Criteria	Code (3 th Edition) Residential and Non-Residential Building Criteria																								
9. OTHER GREEN FEATURES RB 5-1 NRB 5-1	No Provision	<u>NEW CRITERIA UNDER RB 5-1 and NRB 5-1</u> 1 point allocated for the computation of concrete usage index of the development																								
Criteria / Requirements	Code (2 nd Edition) Non-Residential Building Criteria	Code (3 th Edition) Non-Residential Building Criteria – Transit Stations																								
10. NEW CRITERIA FOR TRANSIT STATIONS	No prior provision that caters specially for transit stations under Non Residential Building Criteria	<u>NEW PROVISION</u> New criteria on Transit Stations comprise five environmental impact categories namely Energy Efficiency, Water Efficiency, Environmental Protection, Indoor Environmental Quality and Other Green Features that cater to the design and construction of Transit Station were incorporated. Prerequisite requirements on the minimum design system efficiency (DSE) of air-conditioning system are stipulated and outlined below : (i) For Transit Stations using Water Cooled Chilled-Water Plant: <table border="1" data-bbox="1294 858 2011 1070"> <thead> <tr> <th rowspan="3">Minimum Central Chilled-Water Plant Efficiency</th> <th colspan="3">Peak Building Cooling Load (RT)</th> </tr> <tr> <th>< 300</th> <th>≥ 300 & < 500</th> <th>≥ 500</th> </tr> <tr> <th colspan="3">Design System Efficiency(kW/RT)</th> </tr> </thead> <tbody> <tr> <td></td> <td>0.85</td> <td>0.80</td> <td>0.7</td> </tr> </tbody> </table> (ii) For Transit Stations using Unitary Air-Conditioners: <table border="1" data-bbox="1294 1134 2011 1331"> <thead> <tr> <th rowspan="3">Minimum System Efficiency of Unitary Air-Conditioners</th> <th colspan="2">Peak Building Cooling Load (RT)</th> </tr> <tr> <th>< 500</th> <th>≥ 500</th> </tr> <tr> <th colspan="2">Design System Efficiency(kW/RT)</th> </tr> </thead> <tbody> <tr> <td></td> <td>0.90</td> <td>0.80</td> </tr> </tbody> </table>	Minimum Central Chilled-Water Plant Efficiency	Peak Building Cooling Load (RT)			< 300	≥ 300 & < 500	≥ 500	Design System Efficiency(kW/RT)				0.85	0.80	0.7	Minimum System Efficiency of Unitary Air-Conditioners	Peak Building Cooling Load (RT)		< 500	≥ 500	Design System Efficiency(kW/RT)			0.90	0.80
Minimum Central Chilled-Water Plant Efficiency	Peak Building Cooling Load (RT)																									
	< 300	≥ 300 & < 500		≥ 500																						
	Design System Efficiency(kW/RT)																									
	0.85	0.80	0.7																							
Minimum System Efficiency of Unitary Air-Conditioners	Peak Building Cooling Load (RT)																									
	< 500	≥ 500																								
	Design System Efficiency(kW/RT)																									
	0.90	0.80																								