



CBPU/1.16

20 Sep 2000

ANNEX 2

Tel: 7319675

President
The Institution of Engineers Singapore
70 Bukit Tinggi Road
Singapore 289758
(Fax 4671108)

Controller
Building Control Unit, JTC
The JTC Summit
8 Jurong Town Hall
Singapore 609434
(Fax 8855931)

President
Association of Consulting Engineers Singapore
51 Anson Road #02-65
Anson Centre
Singapore 079904
(Fax 3242581)

Chief Architects
Architectural Department, HDB
3541 Jln Bukit Merah
HDB Centre
Singapore 159459
(Fax 2780943)

President
Singapore Institute of Architects
79 Neil Road
Singapore 088904
(Fax 2262663)

Chief Civil Engineer
Civil Engineering Department
3541 Jln Bukit Merah
HDB Centre
Singapore 159459
(Fax 2797718)

Dear Sirs,

CBPU CIRCULAR (9/2000)**AMENDMENTS TO FORMS:**

- a. APPLICATION FOR CLEARANCE CERTIFICATE FOR DP ON SEWERAGE
- b. CERTIFICATE OF SUPERVISION AND INSPECTION FOR SANITARY/ SEWERAGE WORKS

We refer to our earlier Circular (8/2000) dated 4 Aug 2000 on the implementation of new standard application forms for application to CBPU for BP clearances and TOP/CSC clearances from 1 Oct 2000.

2 There was a recent incident of water contamination at Bukit Timah Plaza. Investigations into the incident revealed that leakage of wastewater from sanitary pipes which ran across potable water tanks had caused the contamination. Please note that such design of sanitary pipes running above potable water tank is not allowed under the Code of Practice on Sewerage and Sanitary Works (1st Edition-Mar 2000).

3 We have amended the **Application Form for Clearance Certificate for DP on Sewerage** and the **Certificate of Supervision and Inspection for Sanitary/Sewerage Works (Form C/QP/SEW)** by inserting a "there is no sanitary pipe located directly above any water tanks" in the standard endorsement of these forms. This is to remind QPs of the requirement not to construct sanitary pipes/floor traps over potable water tanks

4 The amended Application Form and Form C/QP/SEW have been posted on CBPU website at <http://www.cnv.gov.sg/cbpu> under the section on Forms. We appreciate it if you could disseminate this circular to your members and staff.

5 Please feel free to contact our officers Mr Steven Cheong at 7319163 or Ms Koh Mei Leng at 7319622 if you need any further clarification on this matter.

Yours faithfully



LIM KEW LEONG
CHIEF ENGINEER
CENTRAL BUILDING PLAN UNIT

cc **Head , Sewerage Department**
Attn: Mr Steven Cheong