

**MINISTRY OF THE ENVIRONMENT**  
CENTRAL BUILDING PLAN UNIT  
POLLUTION CONTROL DEPARTMENT

CBPU/11.1

18 Apr 96

Mr Rodney Oehlers  
Chairman, M&E Practices Committee  
Association of Consulting Engineers Singapore  
51 Anson Road #11-55  
Anson Centre  
Singapore 079904  
Fax No.: 3242581

Dear Sir

**EJECTOR PUMP ROOM IN BASEMENTS**

Please refer to your letter dated 29 Mar 96.

2 We have referred your request to the Sewerage Department (SD) for consideration. SD's view is that the requirement of a room is intended to enable compliance with functional requirements in the context of safety, security and ease of maintenance.

3 However, I am pleased to inform you that SD has reviewed the requirements, and has decided that while the room would generally be preferred, for cases where a room is not provided, a pit may be used subject to compliance with the functional requirements. The revised requirements pertaining to the room for sewage ejector/solids diverter which also include details of the functional requirements, are at Appendix 1.

4 You may contact Mr Ramasamy of Sewerage Department (Tel: 7319535) if you need any further clarification.



TAN WEE HOCK  
for HEAD  
POLLUTION CONTROL DEPARTMENT

cc  
President, IES  
Attn: ER Ong Ser Huan  
Fax No: 4671108

President, SIA  
Attn: Mr Low Leong Leong  
Fax No: 3368708