

SINGAPORE CIVIL DEFENCE FORCE FIRE SAFETY AND SHELTER DEPARTMENT

HQ SINGAPORE CIVIL DEFENCE FORCE
91 Ubi Avenue 4 Singapore 408827
Website: <http://www.scdf.gov.sg>



Please quote our ref. no. in all future correspondences

CD/FSSD/12/01/03/04

DID: 68481407

FAX: 68481493

18 March 2008

Registrar, Board of Architects (BOA)
Registrar, Professional Engineers Board (PEB)
President, Singapore Institute of Architects (SIA)
President, Institution of Engineers, Singapore (IES)
President, Association of Consulting Engineers, Singapore (ACES)

Dear Sir

AMENDMENT TO THE TECHNICAL GUIDELINES ON FIRE SAFETY REQUIREMENTS FOR PETROLEUM SERVICE STATION

SCDF has made an amendment to the Technical Guidelines on Fire Safety Requirements for Petroleum Service Station. The matter was surfaced to the FSSD Standing Committee meeting held on 10 March 2008.

2 The following will supersede Clause 1.6 of the above guideline.

1.6 Convenience stores integrated with the petroleum service station is limited to 150 square meters.

3 We would appreciate it if you could convey the contents of this circular to members of your organisation. This amendment shall take immediate effect. For any inquiry or clarification, please contact CPT Aidil Arshad at Tel 68481466.

Yours faithfully,
(Transmitted thru' e-mail)

Poon Keng Soon
Secretary, FSSD Standing Committee
for Commissioner
Singapore Civil Defence Force

SINGAPORE CIVIL DEFENCE FORCE FIRE SAFETY AND SHELTER DEPARTMENT

HQ SINGAPORE CIVIL DEFENCE FORCE
91 Ubi Avenue 4 Singapore 408827
Website: <http://www.scdf.gov.sg>



Please quote our ref. no. in all future correspondences

CC

All members of FSSD Standing Committee
President, REDAS
President, IFE
President, SISV
CEO,BCA
CEO,URA
CEO, HDB
CEO,PSA
CEO,JTC
CE,LTA
CE, TUV SUD PSB-(Attn: Ms Tan Chiew Wan / Mr Lau Keong Ong)
GM, SPRING Singapore-(Attn: Mr Teo Nam Kuan)