

SINGAPORE CIVIL DEFENCE FORCE FIRE SAFETY AND SHELTER DEPARTMENT

HQ SINGAPORE CIVIL DEFENCE FORCE
91 Ubi Avenue 4 Singapore 408827
Website: <http://www.scdf.gov.sg>



please quote our ref. no. in all future correspondences

CD/FSSD/12/01/03/04

DID: 68481407

FAX: 68481493

08 July 2008

Registrar, Board of Architects (BOA)
Registrar, Professional Engineers Board (PEB)
President, Singapore Institute of Architects (SIA)
President, Institution of Engineers, Singapore (IES)
President, Association of Consulting Engineers, Singapore (ACES)

Dear Sir / Mdm

INSTALLATION OF FIRE DOOR ON DRY WALL

1. After the issuance of the circular on "Mounting of Fire Damper on Dry Wall" on 6 May 2008, some members of the FSSD Standing Committee asked whether the same could be applied to fire rated doors as they are also normally tested with masonry wall.

2. The Committee had discussed the proposal on 12 May 08 and agreed that fire door shall first be tested with a fire-rated dry-board wall system before it is allowed to be installed in such a system. Subsequent installation of the tested fire door on other fire-rated dry board systems can be considered via assessment reports instead of conducting separate fire tests.

3. This circular shall take immediate effect. Please convey the contents of this circular to members of your Institution/Association/ Board. This circular is also available in CORENET-e-Info: <http://www.corenet.gov.sg/einfo>.

4. For any inquiry or clarification, please contact Maj Choh Choon Jin at tel. no. 68481454 or email address Choh_Choon_Jin@scdf.gov.sg.

Yours faithfully

(transmitted via e-mail)

Poon Keng Soon
Secretary, FSSD Standing Committee
for Commissioner
Singapore Civil Defence Force

cc

All members of FSSD Standing Committee

President, REDAS

President, IFE

President, SISV

CEO, BCA

CEO, URA

CEO, HDB

CEO, PSA

CEO, JTC

CE, LTA

CE, TUV SUD PSB – (Attn : Ms Tan Chiew Wan/Mr. Lau Keong Ong)

CE, SPRING Singapore – (Attn : Mr. Teo Nam Kuan)