

Your Ref: CD/FSSD/12/02/03/01

**Date** : 19 January 2018

Registrar, Board of Architects

Registrar, Professional Engineers Board

President, Singapore Institute of Architects

President, Institution of Engineers, Singapore

President, Association of Consulting Engineers, Singapore

Dear Sir/Mdm

# AMENDMENT TO TECHNICAL REQUIREMENTS FOR STOREY SHELTERS (TR SS) 2015: REMOVAL OF PROVISION OF RADIO OUTLETS

Under Clause 2.6.1 "General" of the current Technical Requirements for Storey Shelter (TR SS) 2015, radio outlets are required to be provided in compliance with the relevant local Codes of Practice for Info-communication Facilities in Building (COPIF) and statutory requirements for the specified peacetime usage. With the implementation of COPIF 2013, radio outlets are no longer required to be provided in residential dwelling units.

- 2. To align the telecommunication requirements for TR SS 2015 with COPIF 2013, this circular is to inform the building industry on the removal of radio outlets within the SS. This is also consistent with the issuance of the Technical Requirements for Household Shelters (TRHS) 2017 in November 2017 where radio outlets are no longer required in the HS. Hence, Clause 2.6.1, together with other relevant clauses, of the TR SS 2015 will be amended as shown in <u>Annex A</u>. This shall take immediate effect from the date of this circular.
- 3. Please convey the contents of this circular to members of your Institution/Association/ Board. The circular is also available in CORENET-e-Info: <a href="http://www.corenet.gov.sg/einfo">http://www.corenet.gov.sg/einfo</a>. For any inquiry or clarification, please contact the undersigned at 6848 1478.









SCDF – A member of the Home Team



Yours faithfully,

(transmitted via e-mail)

MAJ Andy Tan
Fire Safety & Shelter Department
for Commissioner
Singapore Civil Defence Force

cc

CEO, BCA
CEO, URA
CEO, HDB
President, IFE
President, SISV
SCDF Fire Safety Standing Committee
Fire Code Review Committee
Shelter Codes Review Committee











#### Annex A

#### **Existing** Revised Clause 2.6.1: General Clause 2.6.1: General "The following electrical and communication "The following electrical and communication fixtures (Refer to Figure 2.6.1, Figure fixtures (Refer to Figure 2.6.1, Figure 2.12.2(a), Figure 2.12.2(d) & Figure 2.12.2(f)) 2.12.2(a), Figure 2.12.2(d) & Figure 2.12.2(f)) in steel or PVC conduit system shall be in steel or PVC conduit system shall be provided inside each SS, S/C SS or scissor S/C provided inside each SS, S/C SS or scissor S/C SS compartment to provide adequate basic SS compartment to provide adequate basic stay-in and/or communication facilities: stay-in and/or communication facilities: (a) 13A switch socket outlets; (a) 13A switch socket outlets; (b) Switch and lighting points; (b) Switch and lighting points; (c) TV and radio outlets; (c) TV outlets; (d) Communication line for telephony (d) Communication line for telephony outlet. outlet. The electrical and communication fixtures The electrical and communication fixtures shall be designed...." shall be designed...."











#### Clause 2.6.2: Switch Socket Outlets

# (a) For SS

Three (3) 13A switch socket outlets shall be provided inside each SS. Two switch socket outlets shall be in the vicinity of the TV and radio outlets and communication for telephony outlet located away from the SS door. The third switch socket outlet shall be located near the ventilation sleeve opening. Refer to FIGURE 2.6.1.

# (b) For S/C SS

Three (3) 13A switch socket outlets shall be provided inside each S/C SS compartment. At least one switch socket outlet shall be provided at the main landing. The other two switch socket outlets shall be provided at the intermediate landing together with the TV and radio outlets and communication for telephony outlet. Refer to FIGURE 2.12.2 (a) and 2.12.2(d) for details.

## (c) For Scissor S/C SS

Three (3) 13A switch socket outlets shall be provided inside each scissor S/C SS compartment. At least one switch socket outlet shall be provided at the main landing at the upper floor of the SS compartment. The other two switch socket outlets shall be provided at the main landing, together with the TV and radio outlets and communication for telephony outlet at lower floor of the SS compartment. Refer to FIGURE 2.12.2(f) for details.

#### Clause 2.6.2: Switch Socket Outlets

# (a) For SS

Three (3) 13A switch socket outlets shall be provided inside each SS. Two switch socket outlets shall be in the vicinity of the TV outlets and communication for telephony outlet located away from the SS door. The third switch socket outlet shall be located near the ventilation sleeve opening. Refer to FIGURE 2.6.1.

# (b) For S/C SS

Three (3) 13A switch socket outlets shall be provided inside each S/C SS compartment. At least one switch socket outlet shall be provided at the main landing. The other two switch socket outlets shall be provided at the intermediate landing together with the TV outlets and communication for telephony outlet. Refer to FIGURE 2.12.2 (a) and 2.12.2(d) for details.

## (c) For Scissor S/C SS

Three (3) 13A switch socket outlets shall be provided inside each scissor S/C SS compartment. At least one switch socket outlet shall be provided at the main landing at the upper floor of the SS compartment. The other two switch socket outlets shall be provided at the main landing, together with the TV outlets and communication for telephony outlet at lower floor of the SS compartment. Refer to FIGURE 2.12.2(f) for details.











#### Clause 3.6.1 Electrical Services:

"...... Where fixture in the SS are exposed on internal walls and slab, non-metallic inserts are to be used for their mounting. For embedded service cables and fixtures serving the SS, the details shall be as shown in FIGURE 3.5.4(e). The encasement of switch socket outlets, TV and radio outlets, communication line for telephony outlet and switches of Clause 2.6 shall be galvanised steel. Refer to FIGURE 3.6.1(b)......"

#### Clause 6.4 Commissioning Requirements:

"All electrical and communication fixtures such as switch and lighting point, switched socket outlets, TV and radio outlets and communication line for telephony outlet, including SS door notice, rescue hatch (applicable to SS), blast hatch (applicable to S/C SS and scissor S/C SS) shall be provided inside the completed SS. The service conduits with electrical cables serving the SS shall be provided prior to commissioning......"

#### Clause 3.6.1 Electrical Services:

".....Where fixture in the SS are exposed on internal walls and slab, non-metallic inserts are to be used for their mounting. For embedded service cables and fixtures serving the SS, the details shall be as shown in FIGURE 3.5.4(e). The encasement of switch socket outlets, TV outlets, communication line for telephony outlet and switches of Clause 2.6 shall be galvanised steel. Refer to FIGURE 3.6.1(b)......"

# Clause 6.4 Commissioning Requirements:

"All electrical and communication fixtures such as switch and lighting point, switched socket outlets, TV outlets and communication line for telephony outlet, including SS door notice, rescue hatch (applicable to SS), blast hatch (applicable to S/C SS and scissor S/C SS) shall be provided inside the completed SS. The service conduits with electrical cables serving the SS shall be provided prior to commissioning......"







